



Certificate of Analysis

Analysis Report of Sodium Hypochlorite

Sr No.	Characteristics	UOM	Specifications
1	Sp. Gravity at 25 degree celcius	-	1.17 Min
2	Available Chlorine as (Cl)	g/l	120 Min
3	Free alkali (as NaOH)	g/l	10 Min

For any further clarification in this regards please do feel free to contact us at any point of time at info@arrowfinechemicals.com.

Assuring you great attention at all times.

For Arrow Fine Chemicals

Quality Assurance Department

** Note : This is a computer generated report hence not needed to sign.

